

ADDENDUM #1

ALICE T. VIRTUE MEMORIAL POOL & CLINT D. SITZMANN MEMORIAL KIDDIE POOL POOL PAINTING

ADDENDUM #1
15 FEBRUARY 2019
NUMBER OF PAGES: 1

NOTICE:

This addendum is issued to modify, explain or correct the original drawings, specifications and/or previous addenda and is hereby made part of the Contract Documents. **Please attach this Addendum to the specifications in your possession and note receipt of the Addendum on the first page of your bid.**

BID DOCUMENT

CLARIFICATION BASED ON QUESTIONS RECEIVED

- 1. The Bid requests pool painting. May bids for other coating options be submitted as alternates?**

A: Yes. Our current direction is to focus on epoxy painting all pool surfaces, but we are open to receiving and considering alternative coating proposals.

- 2. Clarification of "Full Blast vs. Dust or Brush Blast" and expectation of surface condition.**

A: Overall, we are looking to remove all loose paint from the existing surface. If paint is not easily removed, it may remain. This is subject to inspection and approval by city staff.

- 3. Clarification of Wet Sand Blasting**

A: Wet sand blasting in this bid is referencing sand blasting and adding water. It is NOT water blasting and adding sand.

- 4. Tile swim lanes**

A: Screen off the swim lane tile area. We will not be brush blasting nor epoxy painting over the tiles.

- 5. City Hall closed Monday, February 18, 2019 in observance of President's Day.**

A: Please note that Galena City Hall will be closed on Monday, February 18, 2019. Any questions or delivery of bids should be planned for our standard working hours. The final bid remains due at the original date and time listed, 10 a.m. on Wednesday, February 20, 2019.

End of Addendum