

ADDENDUM NO. 4



www.iiwengr.com

To: All Plan Holders of Record and Interested Parties
City of Galena, Illinois
Project: East Side Utility System Improvements
IIW Project No.: 17054
Issue Date: April 2, 2020

ARCHITECTURE
CIVIL ENGINEERING
CONSTRUCTION SERVICES
ENVIRONMENTAL ENGINEERING
LAND SURVEYING
MUNICIPAL ENGINEERING
STRUCTURAL ENGINEERING
TRANSPORTATION ENGINEERING

The following additions, revisions, corrections, and clarifications contained herein shall become part of the Construction Contract Documents for the Project, and shall be included in the Scope of Work and Bid Proposals to be submitted. References made below to Specifications and Construction Drawings shall be used as a general guide only. Bidders shall determine for themselves the full scope of work affected by the Addendum items.

The following Addendum is part of the Construction Contract Documents.

This Addendum consists of the following:

Addendum No. 4 – 2 pages
Revised Bid Schedule – 1 page

CHANGES TO CONTRACT DOCUMENTS:

1. REVISED BID SCHEDULE: Bid Item 35 is being modified to be 12" PVC Casing (Trenched Inc. Spacers, End Seals, etc.) and the quantity for this bid item is being adjusted. There will be no 20" PVC Casing on the project. Additionally, the quantity for Bid Items 33 and 34 have been modified. These quantities have been modified in accordance with plan modifications identified below. The bid schedule that was included in Addendum #3 inadvertently modified the sidewalk thicknesses (bid items #11, 16 and 17) from what was included in Addendum #1. The revised bid schedule reflects the correct sidewalk thicknesses from Addendum #1. Bidders are required to use the attached Revised Bid Schedule.

CHANGES TO TECHNICAL SPECIFICATIONS:



1. PAGE SPR - 1 of 4: The following shall be added to this page of the Special Project Requirements for the Sanitary Sewer portion of the project:
SANITARY SEWER LATERALS: The project includes the replacement of an anticipated seven (7) sanitary sewer laterals. Sanitary sewer laterals will be paid for under the bid item: 4" PVC SDR 26 Sanitary Sewer Service Laterals. The proposed gasketed wyes in the sanitary sewer main and connections to the existing sanitary sewer lateral utilizing a flexible coupling with stainless steel shear band shall be considered incidental to the sanitary sewer lateral installation.
2. PAGE SPR – 3 of 4: The following shall be added to the Water Service Lines paragraph under Section 40.
There are two water services that are planned to be directionally drilled utilizing bid item number 45 (1" Water Service Line (Directionally Drilled)). The two water services are to be located on plan sheet C5.15, they consist of the two services that extend to the north across Decatur Street.

CHANGES TO DRAWINGS:

1. PLAN SHEET C5.03: The precast manhole details identify that a rubber gasket is required in all manhole sidewall joints. The Contractor may use alternate methods to the identified rubber gasket, but alternate methods must comply with the requirements included in Section 32-4.01 of the Standard Specifications for Water and Sewer Construction in Illinois 7th Edition, 2014.
2. PLAN SHEET C5.11: The PVC Casing identified on this plan sheet is listed as 20" PVC DR25 Casing. The PVC Casings on this page shall be 18" PVC DR25 Casing.

- 3. PLAN SHEET C5.12: The 16" PVC Casing identified on this plan sheet, located at approximate station 6+10, shall be modified to be 12" PVC DR25 Casing.
- 4. PLAN SHEET C5.14: The 16" PVC Casing identified on this plan sheet, located at approximate station 44+80, shall be modified to be 12" PVC DR25 Casing.

It is required to acknowledge this addendum on the Bid Proposal Form.

	FOR IIW, P.C. 
	Geoffry T. Blandin, P.E. License Number 062-057265 Licensed Professional Engineer of Illinois My license renewal date is 11/30/2021 Pages or sheets covered by this seal: Addendum No. 4
	4/2/2020 Date

END OF ADDENDUM NO. 4

BIDDER agrees to perform all the work described in the CONTRACT DOCUMENTS for the following unit prices or indicated sums:

**CITY OF GALENA, ILLINOIS
EAST SIDE UTILITY SYSTEM IMPROVEMENTS
BID SCHEDULE
REVISED PER ADDENDUM NO. 4**

NO.	DESCRIPTION	QUANTITY	UNIT PRICE	TOTAL PRICE
MISCELLANEOUS				
1	Mobilization & Miscellaneous	1 LS	_____	_____
2	Traffic Control	1 LS	_____	_____
3	Erosion Control	1 LS	_____	_____
4	Topsail: Strip, Salvage & Respread (4" Thickness)	1 LS	_____	_____
5	Seed, Fertilize & Mulch	1 LS	_____	_____
6	Exploratory Excavation	50 HRS	_____	_____
7	Remove Hydrant	10 EA	_____	_____
			Miscellaneous Subtotal	_____
PAVING				
8	3" HMA Driveway Pavement, Remove and Replace	20 SY	_____	_____
9	HMA Pavement (4" Thickness)	2420 TON	_____	_____
10	PCC Pavment (7" Thickness)	205 SY	_____	_____
11	PCC Sidewalk (5" Thickness, Remove and Replace)	330 SY	_____	_____
12	Stone Base (HMA Pavement & PCC Curb & Gutter)	6610 TON	_____	_____
13	Remove and Replace PCC Curb & Gutter	1685 LF	_____	_____
14	Pavement Removal	10320 SY	_____	_____
15	Full-Depth Sawcut	780 LF	_____	_____
16	PCC Sidewalk (7" Thickness)	12 SY	_____	_____
17	PCC Sidewalk (5" Thickness)	125 SY	_____	_____
18	ADA Sidewalk Detectable Warning	100 SF	_____	_____
			Paving Subtotal	_____
SANITARY SEWER				
19	4" PVC SDR 26 Sanitary Sewer Service Laterals	200 LF	_____	_____
20	8" PVC SDR 26 Sanitary Sewer	510 LF	_____	_____
21	8" PVC SDR 26 Sanitary Sewer, Spot Repairs	300 LF	_____	_____
22	48" I.D. Manhole	16 VF	_____	_____
23	48" Manhole Base	2 EA	_____	_____
24	Connect to Existing Sanitary Sewer Pipe	30 EA	_____	_____
25	Connect to Existing Sanitary Sewer Manhole	2 EA	_____	_____
26	Adjustment to Existing Sanitary Manhole	2 EA	_____	_____
27	Select Trench Backfill - Sanitary Sewer	960 LF	_____	_____
			Sanitary Sewer Subtotal	_____
WATER MAIN				
28	4" PVC C900 DR18 Water Main w/ Tracer Wire	20 LF	_____	_____
29	6" PVC C900 DR18 Water Main w/ Tracer Wire	950 LF	_____	_____
30	8" PVC C900 DR18 Water Main w/ Tracer Wire	500 LF	_____	_____
31	10" PVC C900 DR18 Water Main w/ Tracer Wire	2600 LF	_____	_____
32	6" DIP Hydrant Lead CL 50 w/ Tracer Wire	250 LF	_____	_____
33	16" PVC Casing (Trenched Inc. Spacers, End Seals, etc.)	30 LF	_____	_____
34	18" PVC Casing (Trenched Inc. Spacers, End Seals, etc.)	300 LF	_____	_____
35	12" PVC Casing (Trenched Inc. Spacers, End Seals, etc.)	55 LF	_____	_____
36	16" Steel Casing (Bored and Jacked - Inc. Spacers, End Seals, etc.)	78 LF	_____	_____
37	Boring Set-Up (for 16" Steel Casing)	1 LS	_____	_____
38	Fire Hydrant, Complete	12 EA	_____	_____
39	6" MJ RS Gate Valve	17 EA	_____	_____
40	8" MJ RS Gate Valve	1 EA	_____	_____
41	10" MJ RS Gate Valve	15 EA	_____	_____
42	Water Main Fittings, Compact DI	4920 LBS	_____	_____
43	Connect To Existing Water Main	14 EA	_____	_____
44	1" Water Service Line	1840 LF	_____	_____
45	1" Water Service Line (Directionally Drilled)	100 LF	_____	_____
46	Insulate Pipe at Catch Basin	1 EA	_____	_____
47	1" Curb Stop	63 EA	_____	_____
48	Select Trench Backfill, Water Main	4740 LF	_____	_____
49	1" Corporation Stop with Saddle	63 EA	_____	_____
50	Tracer Wire Access Box	12 EA	_____	_____
			Water Main Subtotal	_____
TOTAL OF BID				

This bid schedule accompanies the bid proposal of _____