ADDENDUM #1

2023 BOILER REPLACEMENT AT GALENA FIRE DEPARTMENT

ADDENDUM #1 DECEMBER 15, 2023 NUMBER OF PAGES: 1

NOTICE:

This addendum is issued to modify, explain or correct the original drawings, specifications and/or previous addenda and is hereby made part of the Contract Documents. Please attach this Addendum to the specifications in your possession and note receipt of the Addendum on the first page of your bid.

ADD:

- 2. Recommended or equal:
 - Weil McLain Ultra 299 or comparable brand cast aluminum block boiler with 92.5% Annual Fuel Utilization Efficiency and pump, 30 PSI ASME relief valve, drain valve, stainless steel burner with woven steel fiber mesh, direct spark ignition, variable speed blower assembly, Venturi mixing system with air silencer, negative pressure regulated gas valve, 50 VA transformer, dual scale temperature and pressure gauge, outlet water temperature sensor, inlet water temperature sensor, flue gas temperature sensor, outdoor temperature sensor, system water temperature sensor, fully removable jacket front, adjustable boiler legs, on/off power switch, condensate trap with drain tell assembly, propane conversion orifice, and any other parts and equipment necessary for the installation.

End of Addendum