



City of Galena
101 Green Street
Galena, Illinois 61036
815.777.1050

Turner Hall HVAC Replacement Project Questions and Answers

Question No.	Date submitted	Question	Answer
1	11-14-23	Is this the only documentation available for this project?	Yes
2	11-14-23	Where do we bring the sealed bids on Dec. 5 th ?	Galena City Hall, 101 Green Street, Galena
3	11-14-23	The way I am reading this, it says remove (2) 40-ton units and install (1) new 50-ton unit in its place. Is this correct?	Yes
4	11-14-23	The RFQ also asks for a return drop from the ducting system. Is there a desired location for this duct drop?	We are attempting to get as close to the floor as possible with the return drop but are asking contractors to submit their design for the construction of the duct system.
5	11-14-23	Will we need to frame this return ducting in with drywall and finish wall paint?	Yes.



City of Galena
101 Green Street
Galena, Illinois 61036
815.777.1050

Question No.	Date submitted	Question	Answer
6	11-14-23	Currently what kind of controls do you have in the building?	We currently have Honeywell RedLINK Internet Gateway and VisionPRO Series with RedLINK thermostats.
7	11-17-23	Where are the entrances to the ceiling crawl space?	One above the balcony and one in the center of the main floor ceiling.