

ADDENDUM #1

SIDEWALK REPLACEMENT PROGRAM 2023

ADDENDUM #1
FEBRUARY 3, 2023
NUMBER OF PAGES: 1

NOTICE:

This addendum is issued to modify, explain or correct the original drawings, specifications and/or previous addenda and is hereby made part of the Contract Documents. **Please attach this Addendum to the specifications in your possession and note receipt of the Addendum on the first page of your bid.**

SPECIAL PROVISIONS, PAGE 44.

GENERAL NOTES, ITEM #9: Mix code IL DOT PVS1 82PCC6930 with slag is acceptable.

STANDARD REINFORCED CONCRETE CROSSWALK DETAIL, PAGE 55

Omit welded wire fabric reinforcement from the crosswalk design.

End of Addendum